Autonics

TEMPERATURE INDICATOR T3NI/T4YI/T4WI/T4WM SERIES

Ν



Thank you very much for selecting Autonics products For your safety, please read the following before using.

Caution for your safety

*Please keep these instructions and review them before using this unit.

*Please observe the cautions that follow;

Warning Serious injury may result if instructions are not followed.

↑ Caution Product may be damaged, or injury may result if instructions

*The following is an explanation of the symbols used in the operation

Acaution:Injury or danger may occur under special conditions.

⚠ Warning

1. In case of using this unit with machineries (Nuclear power control, medical equipment, vehicle, train, airplane, combustion apparatus, entertainment or safety device etc), it requires installing fail-safe device, or contact us for information on type required.


It may result in serious damage, fire or human injury.

- 2. This equipment must be mounted on panel.
- It may give an electric shock
- 3. Do not repair or checkup when power on.
- It may give an electric shock
- 4. Do not disassemble and modify, when it requires. If needs, please contact us.
- It may give an electric shock and cause a fire.
- 5. Please check the terminal No. when connect.
- 6. Lithium battery is used for memory retention in T4WM, therefore do not disassemble or burn it.
- It may cause a fire
- 7. This product is a combined use of 110/220VAC, please check the terminal when connect.
- It may cause a fire.

⚠ Caution

- 1. This equipment shall not be used outdoors.
- It might shorten the life cycle of the product or give an electric shock 2. When wire connection, No. 20AWG(0.50mm²) should be used and screw bolt on terminal block with 0.74N · m to 0.90N · m strength.
- It may result in malfunction or fire due to contact failure. 3. Please observe specification rating.
- It might shorten the life cycle of the product and cause a fire.
- 4. In cleaning the unit, do not use water or an oil-based detergent. It might cause an electric shock or fire that will result in damage to this product
- 5. Do not use this unit at place where there are flammable or explosive gas, humidity, direct ray of the sun, radiant heat, vibration, impact etc.
- It may cause a fire or explosion
- 6. Do not inflow dust or wire dregs into inside of this unit.
- It may cause a fire or mechanical trouble
- 7. Please wire properly after checking the polarity of terminals when connect thermocouples.
- It may cause a fire or explosion
- *The above specification are changeable without notice anytime.

Ordering information



Specification

Model

Sensor

input type

Standard

scale

range

(℃)

1600

1200

1000

800

600

400

200

100

-100

Model		T3NI	T4YI	T4WI	T4WM	
Power supply		12-24VDC	100-240VAC 50/60Hz	110/220VAC 50/60Hz		
Allowable operating voltage		90 to 110% of rated voltage				
Power consumption		2W	3VA			
Display method			7 Segment LED Display			
Display accuracy		F • S ±0.3% rdg ±1digit	F • S ±0.5% rdg ±1digit			
Input sensor		RTD: Pt100Ω	Thermocouples : K(CA), J(IC), Pt100Ω			
Input line resistance		RTD:Max. 5Ω per a wire	Thermocouples : Max. 10Ω RTD : Max. 5Ω per a wire			
Available sensor quantity					Thermocouple: Max. 5pcs RTD:Max. 5pcs	
Insulation resistance		Min. 100MΩ (at 500VDC)				
Dielectric strength		2000VAC 50/60Hz for 1 minute				
Noise strength		± 2 kV the square wave noise(pulse width:1 μ s) by the noise simulator				
		±500V	±1kV			
Vibra	Mechanical	0.75mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 1 hour				
-tion	Malfunction	0.5mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 10 minutes				
Shock	Mechanical	300m/s² (Approx. 30G) 3 times at X, Y, Z direction				
	Malfunction	100m/s² (Approx. 10G) 3 times at X, Y, Z direction				
Ambient temperature		-10 to 50℃(at non-freezing status)				
Storage temperature		-25 to 65℃(at non-freezing status)□				
Ambient humidity		35 to 85%RH				
Weight		Approx. 34g	Approx. 170g	Appre	ox. 322g	

Temperature range for each sensor

RTD

Pt100.0

99.9℃

–99.9℃

399℃

T4YI / T4WI / T4WM

Pt100Ω

199.9℃

-99.9℃

399℃

Thermocouples


K(CA)

J(IC)

500℃

Connection

1200



111.6

Dimension

©T3NI

⊕T4YI

⊃T4WI

©T4WM

Parts name(T4WM)



- 23456: Position indication-Indicating the temperature value for position of each sensor(LED ON)
- ①: Auto Time adjuster(1 to 10sec)
- 8 : Selection switch 9: PV(Display)

5 Point indicator(T4WM)

OMode selection


(Unit:mm)

●Panel cut-out


●Panel cut-out

Min. 116


- How to select the auto mode and manual mode
- The select switch is ON for 3sec.



•Manual selection: Touch the select switch



Auto selection: Display value for each sensor is changed automatically




*CK: Automatic time adjustment OSelection of input sensor by inner DIP switch

Sensor Switching	2	3	4	5
SW	3 2 1	3 2 1	3 2 1	3 2 1
	ON OFF	ON	ON OFF	ON

Caution for using

- 1. Installation environment
- (1) It shall be used indoor
- ②Altitude Max. 2000m
- ③Pollution Degree 2
- ④Installation Catergory II
- 2 Please use the terminal (M3.5 Max 7.2mm) when connect the AC power source



- 4 Please install power switch or circuit—breaker in order to cut power supply
- 5. The switch or circuit-breaker should be installed near by users 6. Do not use this product as Volt-meter or Ampere-meter, this is a temperature
- controller 7 Be sure to use compensating wire when extends wire from controller
- otherwise the temperature deviation will be occurred at the part where wires are connected each other.
- 8. In case of using RTD sensor, 3wire type must be used.
- If it needs to extend the line, 3wires must be used with the same thickness as the line. It might cause the deviation of temperature if the resistance of line is different
- 9. In case of making power line and input signal line close, line filter for noise protection should be installed at power line and input signal line should be
- 10. Keep away from the high frequency instruments. (High frequency welding machine & sewing machine, big capacitive SCR controller)
- *It may cause malfunction if above instructions are not followed.

Main products

- COUNTER
- PANEL METER
- **■** TACHOMETER
- PHOTOELECTRIC SENSOR
- FIBER OPTIC SENSOR
- PRESSURE SENSOR
- ROTARY ENCODER
- SENSOR CONTROLLER
- STEPPING MOTOR & DRIVER
- POWER CONTROLLER

Autonics Corporation http://www.autonics.net

■HEAD QUARTER

41-5, Yongdang-Ri, Ungsang-Up, Yangsan-Shi Kyung-Nam, Korea 626-847.

■TRADE DEPARTMENT :

511 Ansung B/D, 410-13, Shindolim-Dong, Kuro-Gu, Seoul, Korea 152-070

TEL:82-2-679-6585 / FAX:82-2-679-6556 ■F-mail: sales@autonics.net

- TEMPERATURE CONTROLLER
- LINE SPEED METER
- DISPLAY UNIT
- PROXIMITY SWITCH

- & CONTROLLER

NO20020606-EP-KE-03-0040D